

Radiant Efficiency Test Result

According to the European Standard EN 416-2
(Gas fired overhead radiant tube heater – rational use of energy)

Manufacturer **Officine Termotecniche Fraccaro srl**

Appliance **PANRAD**

Model	Test report number	Radiant efficiency
FRA2	23-IMQ-01 S3	62.8 %
FRA3	24.1-IMQ-01 S2	67.1 %
FRA4	25.1-IMQ-01 S2	64.5 %
FRA4.1	25.2-IMQ-01 S2	66.6 %
FRA5	25.4-IMQ-01 S6	67.9 %
FRB3	24.2-IMQ-01 S2	63.6 %
FRB4	25.5-IMQ-01 S2	73.0 %
FRB4.1	25.3-IMQ-01 S2	68.0 %
FRB5	25.4-IMQ-01 S7	70.3 %
FRC4	25.6-IMQ-01 S2	70.7 %
FRC5	25.4-IMQ-01 S5	72.8 %

Date 2010/02/03

Print Name G. Granzotto

Signature

